



Dennis Acuna, P. E., T. E.
Director of Transportation

COUNTY OF RIVERSIDE

TRANSPORTATION AND LAND MANAGEMENT AGENCY

Hector D. Davila, P.E.
*Deputy for Transportation/
Capital Projects*

Russell Williams
*Deputy for Transportation/
Planning and Development*

Transportation Department

ADDENDUM NUMBER 1

Dated April 4, 2024

**to the
Specifications and Contract Documents
for the construction of**

**Gilman Springs Road Phase 6 Safety Project
From 8,920 Feet S/O Alessandro Boulevard To 5,340 Feet S/O Bridge Street
Eastern Moreno Valley and Gilman Hot Springs Areas
Project No. C2-0161
Federal Aid No. HSIPL-5956 (263)**

**Bids Due: (Revised)
Wednesday, April 17, 2024; 2:00 p.m.
14th Street Transportation Annex
3525 14th Street; Riverside, CA 92501
(951) 955-6780**

This Addendum is issued pursuant to the Instructions to Bidders, Item No. 8, of the Contract Documents for the reference project. This Addendum is issued as a supplement to the specification and special provisions for the referenced project. The revisions to the specifications shall become a part of the Contract Documents, and each bidder shall acknowledge receipt thereof on the Bid (Proposal). Bidders are directed to sign this addendum as acknowledged and attach the signed addendum to the contractor's submitted proposal.

Note: During the advertisement period of this project, this document and attachments (if any) are available upon request at the office of the Transportation Department, and are available as a free download at the Transportation Department's website:

<https://trans.rctlma.org/notices-inviting-bids>

MODIFICATION TO PROPOSAL:

Item 1: The new designated date and time for the receipt and opening of bids is revised as follows:

**Wednesday, April 17, 2024; 2:00 p.m.
14th Street Transportation Annex
3525 14th Street; Riverside, CA 92501
(951) 955-6780**

Item 2: Contractor License Requirement.
Refer to 'Notice to Bidders', page vi in the specifications book.

Delete the License Requirement Paragraph found on the Notice to Bidders and replace it with the following paragraph:

Bids are required for the entire work described herein. The Contractor shall possess a current and active State of California Class "A" Contractor's license **at the time this contract is awarded**. The successful bidder shall furnish a payment bond and a performance bond.

Item 3: DBE Confirmation Forms (Exhibit 9-I) Submittal Deadline.

Refer to Section 17, "Disadvantaged Business Enterprise (DBE)", subsection "Commitment and Utilization" on page A13 of the Instructions to Bidders; also, refer to Form 9-I, DBE CONFIRMATION, on Appendix E, page 19 of 39.

Delete the second paragraph in subsection "Commitment and Utilization" and replace it with the following paragraph:

The bidder shall complete and sign Exhibit 15-G: Construction Contract DBE Commitment form included in the contract documents regardless of whether DBE participation is reported. The bidder shall provide written confirmation from each DBE that the DBE is participating in the Contract. LAPM Exhibit 9-I: DBE Confirmation or equivalent form (See Appendix E) and DBE's quote must be submitted. The written confirmation must be **received by the County no later than 4:00 p.m. on the 4th business day after bid opening**. If a DBE is participating as a joint venture partner, the bidder shall submit a copy of the joint venture agreement.

As a clarification, DBE's written confirmations must be submitted no later than 4:00 p.m. on the 4th business day after bid opening.

Item 4: Clarification – Concrete Bases.

Refer to Section 28-1.01, Concrete Bases, General, on page 50 of the Special Provisions.

The concrete base is called out on various culverts; the provision in Section 28-1.01 is only to be enforced where and if additional conflicts occur. As stated in the payment clause, compensation for furnishing and placing Concrete Base shall be considered as included in the contract price paid per cubic yard for Class 2 Aggregate Base.

Refer to section 9-1.06B, Increases of More Than 25 Percent, of the Standard Specifications, which allows for an increase of up to 25% of the bid quantity without payment adjustment.

Item 5: Steel Bollards Posts.

Refer to Section 75-93, Steel Bollards Posts, sub-section 75-9.03, Construction, on page 84 of the Special Provisions.

Delete the second paragraph of sub-section 75-9.03, and replace it with the following paragraph:

Steel bollard posts shall be **8 feet long, with 5 feet above ground and 3 feet embedded**

in concrete footing. Posts shall be set 3 feet in a block of portland cement concrete. Place a minimum of 3 inches of concrete below the steel bollard post.

Item 6: Smooth Wire on Top of Wildlife Fence.

Refer to Section 80-3, Chain Link Fences, on page 86 of the Special Provisions, and refer to Wildlife Fence details on plan sheets C-28 and C-29.

The following special provisions are added and made a part hereby:

Wildlife fence wire post top detail is revised to require smooth (no barbs) wire instead of barb wire. The fence toppers should be oriented away from Gilman Springs towards open space.

Smooth wire must meet the requirements in Section 80-2.02D, Barbed Wire, but without the barbs.

Full compensation for furnishing and installing smooth wire on top of wildlife fence shall be considered as included in the contract price paid per linear foot for Chain Link Fence (CL-10) [Wildlife Fence 8' High, Buried 2'], and shall include full compensation for furnishing all labor, materials, tools, equipment and incidentals, and for doing all the work involved, complete in place, including all hardware, wire post tops, smooth wire, as shown on the plans, as directed by the Engineer, and no additional compensation will be allowed therefor.

Item 7: Encroachment Permit from the City of San Jacinto.

Refer to Section 00-1.11, Obtain Encroachment Permit, on page 7 of the Special Provisions.

The following paragraph is added to sub-section 00-1.11A, Payment, and made a part hereby:

If the Contractor pays any fees to City of San Jacinto to obtain Encroachment Permit, then full compensation for the actual cost of the Encroachment Permit fees, as paid by the Contractor to City of San Jacinto, shall be paid on a force account basis, under Miscellaneous Work (As Directed) item of work, in accordance with Section 9-1.04 of the Standard Specifications.

Item 8: Update - Federal Prevailing Wages Decision

Refer to Appendix D entitled "Federal Prevailing Wages Decision", pages 1 through 20. Delete and replace these pages with the following:

Federal wage determination, General Decision No. **CA20240025 dated 3/8/2024**, Modification No. 4, attached herewith as **Attachment "A"**, shall apply to this project.

This document is available upon request from the Transportation Department: (951) 955-6780, and also posted on following County website:

<https://trans.rctlma.org/notices-inviting-bids>


Addendum No. 1
Gilman Springs Road Phase 6 Safety Project
From 8,920 Feet S/O Alessandro Boulevard To 5,340 Feet S/O Bridge Street
Eastern Moreno Valley and Gilman Hot Springs Areas
Project No. C2-0161, Federal Aid No. HSIPL-5956 (263)
April 4, 2024
Page 4 of 5

ATTACHMENTS

A – Federal Prevailing Wage Decision - CA20240025 dated 3/8/2024 (20 pages)

This addendum has been prepared under the direction of the following registered Civil Engineer(s):

Recommended by:



Alfredo Martinez, PE
Engineering Project Manager



Concurrence:



Cesar Tolentino, PE
Engineering Division Manager

Acknowledged: _____ **Date:** _____
(Contractor)

JRJ: jrj:jr

Note: Refer to Instruction to Bidders Item No. 8, "Addenda". Submission of all addendum pages and non-bidding document attachments of addendum are not necessary for Bid submittal. Submittal of this acknowledgement page is adequate for Bid reception. Bidders are reminded to list addendum number(s) received on the first page of the Bid form (Proposal).